Commonwealth of Kentucky Division for Air Quality

PERMIT APPLICATION SUMMARY FORM
(For all sources except PSD and true minor sources)
Completed by: Bryan Handy

GENERAL INFORMATION:		
Name:	Duke Energy Marshall County, LLC	
Address:	Intersection of Paducah Louisville Railroad and Highway	
	1523, 4 miles west of Calvert City in Marshall County,	
	Kentucky	
Date application received:	December 9, 1999	
SIC/Source description:	4911/ Electric Generation	
AFS(10-digit) Plant ID:	21-157-00053	
Application log number:	G393	
Permit number:	V-00-020	
APPLICATION TYPE/PERMIT ACTIVIT	Y:	
[X] Initial issuance	[] General permit	
[] Permit modification	[]Conditional major	
Administrative	[X] Title V	
Minor	[] Synthetic minor	
Significant	[] Operating	
[] Permit renewal	[X] Construction/operating	
[] 1 0 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	[12] constraint operating	
COMPLIANCE SUMMARY: [] Source is out of compliant [] Compliance certification APPLICABLE REQUIREMENTS LIST: [] NSR [X] PSD [] Netted out of PSD/NSR	[X] NSPS [] SIP [] NESHAPS [] Other	
MISCELLANEOUS:	or 51:052,1(14)(b)	
[X] Acid rain source		
[] Source subject to 112(r)		
	ally enforceable emissions cap	
11	or alternative operating scenarios	
[] Source subject to a MAC		
· · · · · · · · · · · · · · · · · · ·	y-case 112(g) or (j) determination	
[] Application proposes nev		
[X] Certified by responsible		
[X] Diagrams or drawings in		
	formation (CBI) submitted in application	
[] Pollution Prevention Me		
[] Area is non-attainment ()		

EMISSIONS SUMMARY:

Pollutant	Actual (tpy)	Potential (tpy)
PM	134	134
SO_2	160	160
NOx	655.9	655.9
CO	538.9	538.9
VOC	38.6	38.6
LEAD	.14	.14
H2SO4	18.7	18.7

SOURCE PROCESS DESCRIPTION:

The Marshall County Generating Station, is to include eight (8) General Electric 7EA natural gasfired combustion turbines which are to operate in simple cycle mode with a nominal output capacity of 80 megawatts (MW) each. The facility is to produce electricity during periods of peak electricity demand on a daily and seasonal basis.

EMISSION AND OPERATING CAPS DESCRIPTION:

The plant is to be limited to operating 2500 hours per year or less for each unit. The plant may fire low sulfur diesel fuel as a secondary fuel for up to 500 hours per year for each unit. The plant shall not fire diesel fuel for more than 16 hours in any consecutive 24-hour period. All combustion turbines must be operated at 60% load or greater except during periods of startup, shutdown, and malfunction.

The sulfur content of fuel fired in the combustion turbines must contain less than 0.05% sulfur by weight.

The permittee has accepted NOx BACT emission limits of 12 ppmvd corrected to 15% oxygen on an hourly average and 9 ppmvd corrected to 15% oxygen on a rolling 12-month annual average while burning natural gas. The permittee has also accepted a NOx BACT emission limit of 42 ppmvd corrected to 15% oxygen on an hourly average while burning low sulfur diesel fuel. Additionally, CO emissions shall be limited to 25 ppmvd at 15% oxygen and 20 ppmvd at 15% oxygen on an hourly average while firing natural gas and low sulfur diesel fuel respectively. Particulate emissions from each turbine shall be limited to 10 lbs/hr while firing natural gas and 26 lbs/hr while firing low sulfur diesel fuel.